

<b>CLIENT:</b>	Trace Analytical Laboratories, Inc.	<b>Collection Date</b>	7/1/2025 7:55:00 AM
<b>Project:</b>	25G0138	<b>Received Date:</b>	7/9/2025 11:25:00 AM
<b>Lab ID:</b>	2507724-01	<b>Matrix:</b>	DRINKING WATER
<b>Client Sample ID:</b>	16702 S. Water Tower Dr.	<b>Sampled By:</b>	TW
<b>Location:</b>	Kinross Charter Twp		

Analyses	Result	RL	Qual	Units	MCL	Date Analyzed
----------	--------	----	------	-------	-----	---------------

**FIELD PARAMETERS**

Site Code	TP001
WSSN#	03630

**PFAS, DRINKING WATER**

**EPA 537.1**

Analyst: JS

PFBS	< 2.0	2.0		ng/L		7/15/2025 2:52:00 AM
PFHxA	< 2.0	2.0		ng/L		7/15/2025 2:52:00 AM
HFPO-DA	< 2.0	2.0		ng/L	10	7/15/2025 2:52:00 AM
PFHxS	3.3	2.0		ng/L	10	7/15/2025 2:52:00 AM
PFHpA	< 2.0	2.0		ng/L		7/15/2025 2:52:00 AM
ADONA	< 2.0	2.0		ng/L		7/15/2025 2:52:00 AM
PFOA	< 2.0	2.0		ng/L	4.0	7/15/2025 2:52:00 AM
PFOS	< 2.0	2.0		ng/L	4.0	7/15/2025 2:52:00 AM
PFNA	< 2.0	2.0		ng/L	10	7/15/2025 2:52:00 AM
9CI-PF3ONS	< 2.0	2.0		ng/L		7/15/2025 2:52:00 AM
PFDA	< 2.0	2.0		ng/L		7/15/2025 2:52:00 AM
NMeFOSAA	< 2.0	2.0		ng/L		7/15/2025 2:52:00 AM
NEtFOSAA	< 2.0	2.0		ng/L		7/15/2025 2:52:00 AM
PFUnA	< 2.0	2.0		ng/L		7/15/2025 2:52:00 AM
11CI-PF3OUdS	< 2.0	2.0		ng/L		7/15/2025 2:52:00 AM
PFDoA	< 2.0	2.0		ng/L		7/15/2025 2:52:00 AM
PFTTrDA	< 2.0	2.0		ng/L		7/15/2025 2:52:00 AM
PFTA	< 2.0	2.0		ng/L		7/15/2025 2:52:00 AM
PFAS Hazard Index	0.33	0.20		ng/L	1.0	7/15/2025 2:52:00 AM
Surr: d5-N-EtFOSAA	85.4	70 - 130		%Rec		7/15/2025 2:52:00 AM
Surr: M3HFPO-DA	88.0	70 - 130		%Rec		7/15/2025 2:52:00 AM
Surr: MPFDA	76.8	70 - 130		%Rec		7/15/2025 2:52:00 AM
Surr: MPFHxA	99.0	70 - 130		%Rec		7/15/2025 2:52:00 AM

**Qualifiers:** < Not Detected at the Reporting Limit  
 MCL Maximum Contaminant Level  
 RL Reporting Limit

H Holding times for preparation or analysis exceeded  
 PL Permit Limit

<b>CLIENT:</b>	Trace Analytical Laboratories, Inc.	<b>Collection Date</b>	7/1/2025 9:40:00 AM
<b>Project:</b>	25G0138	<b>Received Date:</b>	7/9/2025 11:25:00 AM
<b>Lab ID:</b>	2507724-03	<b>Matrix:</b>	DRINKING WATER
<b>Client Sample ID:</b>	15946 S. Country Club Dr.	<b>Sampled By:</b>	TW
<b>Location:</b>	Kinross Charter Twp		

Analyses	Result	RL	Qual	Units	MCL	Date Analyzed
----------	--------	----	------	-------	-----	---------------

**FIELD PARAMETERS**

Site Code	TP005
WSSN#	03630

**PFAS, DRINKING WATER**

**EPA 537.1**

Analyst: JS

PFBS	< 2.0	2.0		ng/L		7/15/2025 3:21:00 AM
PFHxA	< 2.0	2.0		ng/L		7/15/2025 3:21:00 AM
HFPO-DA	< 2.0	2.0		ng/L	10	7/15/2025 3:21:00 AM
PFHxS	< 2.0	2.0		ng/L	10	7/15/2025 3:21:00 AM
PFHpA	< 2.0	2.0		ng/L		7/15/2025 3:21:00 AM
ADONA	< 2.0	2.0		ng/L		7/15/2025 3:21:00 AM
PFOA	< 2.0	2.0		ng/L	4.0	7/15/2025 3:21:00 AM
PFOS	< 2.0	2.0		ng/L	4.0	7/15/2025 3:21:00 AM
PFNA	< 2.0	2.0		ng/L	10	7/15/2025 3:21:00 AM
9CI-PF3ONS	< 2.0	2.0		ng/L		7/15/2025 3:21:00 AM
PFDA	< 2.0	2.0		ng/L		7/15/2025 3:21:00 AM
NMeFOSAA	< 2.0	2.0		ng/L		7/15/2025 3:21:00 AM
NEtFOSAA	< 2.0	2.0		ng/L		7/15/2025 3:21:00 AM
PFUnA	< 2.0	2.0		ng/L		7/15/2025 3:21:00 AM
11CI-PF3OUdS	< 2.0	2.0		ng/L		7/15/2025 3:21:00 AM
PFDoA	< 2.0	2.0		ng/L		7/15/2025 3:21:00 AM
PFTTrDA	< 2.0	2.0		ng/L		7/15/2025 3:21:00 AM
PFTA	< 2.0	2.0		ng/L		7/15/2025 3:21:00 AM
PFAS Hazard Index	< 0.20	0.20		ng/L	1.0	7/15/2025 3:21:00 AM
Surr: d5-N-EtFOSAA	90.0	70 - 130		%Rec		7/15/2025 3:21:00 AM
Surr: M3HFPO-DA	91.1	70 - 130		%Rec		7/15/2025 3:21:00 AM
Surr: MPFDA	74.7	70 - 130		%Rec		7/15/2025 3:21:00 AM
Surr: MPFHxA	96.3	70 - 130		%Rec		7/15/2025 3:21:00 AM

**Qualifiers:**

<	Not Detected at the Reporting Limit
MCL	Maximum Contaminant Level
RL	Reporting Limit

H	Holding times for preparation or analysis exceeded
PL	Permit Limit

<b>CLIENT:</b>	Trace Analytical Laboratories, Inc.	<b>Collection Date</b>	7/1/2025 9:00:00 AM
<b>Project:</b>	25G0138	<b>Received Date:</b>	7/9/2025 11:25:00 AM
<b>Lab ID:</b>	2507724-05	<b>Matrix:</b>	DRINKING WATER
<b>Client Sample ID:</b>	15 Greenwood Way	<b>Sampled By:</b>	TW
<b>Location:</b>	Kinross Charter Twp		

Analyses	Result	RL	Qual	Units	MCL	Date Analyzed
----------	--------	----	------	-------	-----	---------------

**FIELD PARAMETERS**

Site Code TP007  
 WSSN# 03630

**PFAS, DRINKING WATER**

**EPA 537.1**

Analyst: JS

PFBS	< 2.0	2.0		ng/L		7/15/2025 4:20:00 AM
PFHxA	< 2.0	2.0		ng/L		7/15/2025 4:20:00 AM
HFPO-DA	< 2.0	2.0		ng/L	10	7/15/2025 4:20:00 AM
PFHxS	2.3	2.0		ng/L	10	7/15/2025 4:20:00 AM
PFHpA	< 2.0	2.0		ng/L		7/15/2025 4:20:00 AM
ADONA	< 2.0	2.0		ng/L		7/15/2025 4:20:00 AM
PFOA	< 2.0	2.0		ng/L	4.0	7/15/2025 4:20:00 AM
PFOS	< 2.0	2.0		ng/L	4.0	7/15/2025 4:20:00 AM
PFNA	< 2.0	2.0		ng/L	10	7/15/2025 4:20:00 AM
9CI-PF3ONS	< 2.0	2.0		ng/L		7/15/2025 4:20:00 AM
PFDA	< 2.0	2.0		ng/L		7/15/2025 4:20:00 AM
NMeFOSAA	< 2.0	2.0		ng/L		7/15/2025 4:20:00 AM
NEtFOSAA	< 2.0	2.0		ng/L		7/15/2025 4:20:00 AM
PFUnA	< 2.0	2.0		ng/L		7/15/2025 4:20:00 AM
11CI-PF3OUdS	< 2.0	2.0		ng/L		7/15/2025 4:20:00 AM
PFDoA	< 2.0	2.0		ng/L		7/15/2025 4:20:00 AM
PFTTrDA	< 2.0	2.0		ng/L		7/15/2025 4:20:00 AM
PFTA	< 2.0	2.0		ng/L		7/15/2025 4:20:00 AM
PFAS Hazard Index	0.23	0.20		ng/L	1.0	7/15/2025 4:20:00 AM
Surr: d5-N-EtFOSAA	92.5	70 - 130		%Rec		7/15/2025 4:20:00 AM
Surr: M3HFPO-DA	93.5	70 - 130		%Rec		7/15/2025 4:20:00 AM
Surr: MPFDA	76.5	70 - 130		%Rec		7/15/2025 4:20:00 AM
Surr: MPFHxA	95.9	70 - 130		%Rec		7/15/2025 4:20:00 AM

**Qualifiers:** < Not Detected at the Reporting Limit  
 MCL Maximum Contaminant Level  
 RL Reporting Limit

H Holding times for preparation or analysis exceeded  
 PL Permit Limit